

## **Exhibit A**

### **Prohibited Wastes**

**Specific Prohibitions.** No Person/Users and/or Customers shall introduce or cause to be introduced into Utility's Sewer System the following pollutants, substances, or wastewater:

- (1) Pollutants which create a fire or explosive hazard, including, but not limited to, waste streams with a closed-cup flashpoint of less than 140°F (60°C) using the test methods specified in 40 CFR 261.21;
- (2) Wastewater having a pH less than 6.0 or more than 10.0, or otherwise causing corrosive structural damage to equipment;
- (3) Wastewater containing a sulfide concentration greater than two milligrams per liter (2.0 mg/L);
- (4) Solid or viscous substances in amounts which will cause obstruction of the flow in the Sewer System resulting in interference;
- (5) Pollutants, including oxygen-demanding pollutants (i.e., BOD) released in a discharge rate and/or pollutant concentration which, either solely or by interaction with other pollutants, will cause interference with the Sewer System;
- (6) Wastewater having a temperature greater than 140°F (60°C), or which will inhibit biological activity in the treatment plant resulting in interference, but in no case wastewater which causes the temperature at the introduction into the treatment plant to exceed 104°F (40°C);
- (7) Petroleum oil, nonbiodegradable cutting oil, or products of mineral oil origin, in amounts that will cause interference or pass through;
- (8) Pollutants which result in the presence of toxic gases, vapors, or fumes within the Sewer System in a quantity that may cause acute worker health and safety problems;
- (9) Any trucked or hauled pollutants without the express permission of the Utility;
- (10) Noxious or malodorous liquids, gases, solids, or other wastewater which, either solely or by interaction with other wastes, are sufficient to create a public nuisance or a hazard to life, or that prevent maintenance or repair;
- (11) Wastewater containing any radioactive wastes or isotopes are prohibited;
- (12) Stormwater runoff, surface wastewater, groundwater, artesian well wastewater, roof runoff, subsurface drainage, swimming pool drainage, condensate, deionized wastewater, noncontact cooling wastewater, and unpolluted wastewater, unless explicitly authorized by the Utility in writing;
- (13) Sludges, screenings, or other residues from the pretreatment of industrial wastes;
- (14) Wastewater causing, solely or in conjunction with other sources, the treatment plant's effluent to fail a toxicity test;
- (15) Detergents, surface-active agents, or other substances which may cause excessive foaming; or
- (16) Fats, oils, or greases of animal or vegetable origin in concentrations greater than 200 mg/L.